



Snelling Merced Falls School CA2400062

Certificate of Analysis

Sample ID: AGF2927-01
Sampled By: Marco Marin
Sample Description: Site-Gym

Sample Date - Time: 06/21/2023 - 06:00

Matrix: Water Sample Type: Grab

BSK Associates Laboratory Fresno

Metals

Analyte	Method	Result	RL	Units	RL Mult	1° MCL	2° MCL	Batch	Prepared	Analyzed	Qual
Copper	EPA 200.8	160	50	ug/L	1		1000	AGF1763	06/27/23	06/28/23	
Lead	EPA 200.8	ND	5.0	ug/L	1			AGF1763	06/27/23	06/28/23	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

AGF2927 FINAL 06292023 1717

Page 3 of 12





Snelling Merced Falls School CA2400062

Certificate of Analysis

Sample ID: AGF2927-02 Sampled By: Marco Marin

Sample Description: Site-Kitchen Sink

Sample Date - Time: 06/21/2023 - 06:01

Matrix: Water

Sample Type: Grab

BSK Associates Laboratory Fresno

Metals

Analyte	Method	Result	RL	Units	RL Mult	1° MCL	2° MCL	Batch	Prepared	Analyzed	Qual
Copper	EPA 200.8	190	50	ug/L	1		1000	AGF1763	06/27/23	06/28/23	
Lead	EPA 200.8	ND	5.0	ug/L	1			AGF1763	06/27/23	06/28/23	





Snelling Merced Falls School CA2400062

Certificate of Analysis

Sample ID: AGF2927-03

Sample Date - Time: 06/21/2023 - 06:03

Sampled By: Marco Marin

Matrix: Water

Sample Type: Grab

Sample Description: Site-Northside of 7-8 Classroom

BSK Associates Laboratory Fresno

Metals

Analyte	Method	Result	RL	Units	RL Mult	1° MCL	2° MCL	Batch	Prepared	Analyzed	Qual
Copper	EPA 200.8	140	50	ug/L	1		1000	AGF1763	06/27/23	06/28/23	
Lead	EPA 200.8	ND	5.0	ug/L	1			AGF1763	06/27/23	06/28/23	





General-EDT
Snelling Merced Falls School CA2400062

Certificate of Analysis

Sample ID: AGF2927-04 Sampled By: Marco Marin

Sample Description: Site-Teacher's Lounge

Sample Date - Time: 06/21/2023 - 06:07

Matrix: Water

Sample Type: Grab

BSK Associates Laboratory Fresno

Metals

Analyte	Method	Result	RL	Units	RL Mult	1° MCL	2° MCL	Batch	Prepared	Analyzed	Qual
Copper	EPA 200.8	ND	50	ug/L	1		1000	AGF1763	06/27/23	06/28/23	
Lead	EPA 200,8	8.9	5.0	ug/L	1			AGF1763	06/27/23	06/28/23	

Page 6 of 12





Snelling Merced Falls School CA2400062

Certificate of Analysis

Sample ID: AGF2927-05

Sampled By: Marco Marin

Sample Description: Site-Drinking Fountain Outside Office

Sample Date - Time: 06/21/2023 - 06:09

Matrix: Water

Sample Type: Grab

BSK Associates Laboratory Fresno

Metals

Analyte	Method	Result	RL	Units	RL Mult	1° MCL	2° MCL	Batch	Prepared	Analyzed	Qual
Copper	EPA 200.8	ND	50	ug/L	1		1000	AGF1763	06/27/23	06/28/23	CONTRACTOR
Lead	EPA 200,8	ND	5.0	ug/L	1			AGF1763	06/27/23	06/28/23	